

Page 1 of 10

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	F1355-28	Reg. No.	012-SC1196-17
Certificate Holder	-		
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT	·	
Name of testing laboratory	RISE		
Subtype title	F1355-28		
Heat Pump Type	Brine/Water and	Water/Water	
Refrigerant	R407c		
Mass Of Refrigerant	4.4 kg		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Model: F1355-28

General Data		
Power supply	1x230V 50Hz	

Brine/Water Heat Pump

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	20.77 kW	19.87 kW	
El input	4.56 kW	6.48 kW	
СОР	4.55	3.07	
Indoor water flow rate	3.58 m³/h	2.14 m³/h	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	47 dB(A)	47 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η _s	198 %	155 %
Prated	28.00 kW	28.00 kW
SCOP	5.07	4.07
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	24.80 kW	25.00 kW
COP Tj = -7°C	4.40	3.10
Pdh Tj = +2°C	15.60 kW	15.30 kW
COP Tj = +2°C	4.90	3.90
Pdh Tj = +7°C	9.70 kW	9.70 kW
COP Tj = +7°C	5.60	4.60
Pdh Tj = 12°C	4.30 kW	4.30 kW
COP Tj = 12°C	6.10	5.30
Pdh Tj = Tbiv	28.00 kW	28.00 kW
COP Tj = Tbiv	4.10	2.80

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 10

This information was generated by the HP KEYMARK database on 17 Dec 2020

-	
28.00 kW	28.00 kW
4.10	2.80
0.98	0.99
65 °C	65 °C
7 W	7 W
50 W	35 W
19 W	19 W
25 W	25 W
electricity	electricity
0.00 kW	0.00 kW
11528 kWh	14621 kWh
	4.10 0.98 65 °C 7 W 50 W 19 W 25 W electricity 0.00 kW

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	47 dB(A)	47 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η _s	211 %	165 %
Prated	28.00 kW	28.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 5 of 10

This information was generated by the HP KEYMARK database on 17 Dec 2020

This mormation was generated by the HP KETMARK database on 17 Dec 2020				
SCOP	5.47	4.32		
Tbiv	-22 °C	-22 °C		
TOL	-22 °C	-22 °C		
Pdh Tj = -7°C	17.00 kW	17.00 kW		
COP Tj = -7°C	5.10	3.90		
Pdh Tj = +2°C	10.30 kW	10.30 kW		
COP Tj = +2°C	5.50	4.50		
Pdh Tj = +7°C	6.60 kW	6.60 kW		
COP Tj = +7°C	6.30	5.40		
Pdh Tj = 12°C	3.80 kW	3.70 kW		
COP Tj = 12°C	5.90	5.40		
Pdh Tj = Tbiv	28.00 kW	28.00 kW		
COP Tj = Tbiv	4.10	2.80		
Pdh Tj = TOL	28.00 kW	28.00 kW		
COP Tj = TOL	4.10	2.80		
Cdh	0.97	0.98		
WTOL	65 °C	65 °C		
Poff	7 W	7 W		
РТО	50 W	35 W		
PSB	19 W	19 W		
РСК	25 W	25 W		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 10

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	12907 kWh	16450 kWh

Water/Water Heat Pump

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	26.68 kW	25.23 kW	
El input	4.76 kW	6.37 kW	
СОР	5.60	3.96	
Indoor water flow rate	4.63 m³/h	2.72 m³/h	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	Medium temperature
η _s	243 %	188 %
Prated	35.00 kW	35.00 kW
SCOP	6.15	4.79
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	31.00 kW	31.00 kW
COP Tj = -7°C	5.40	3.80
Pdh Tj = +2°C	21.60 kW	18.80 kW
COP Tj = +2°C	6.10	4.70
Pdh Tj = +7°C	12.10 kW	12.10 kW
COP Tj = +7°C	6.60	5.50
Pdh Tj = 12°C	7.00 kW	6.80 kW
COP Tj = 12°C	7.70	6.60
Pdh Tj = Tbiv	35.00 kW	35.00 kW
COP Tj = Tbiv	4.90	3.50

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 8 of 10

This information was generated by the HP KEYMARK databa	17 0 0000
I his information was denorated by the HU KEYMAUK databa	$c \cap O \cap I / I \cap O \cap I)$

5		
Pdh Tj = TOL	35.00 kW	35.00 kW
COP Tj = TOL	4.90	3.50
Cdh	0.97	0.99
WTOL	65 °C	65 °C
Poff	7 W	7 W
РТО	65 W	45 W
PSB	19 W	19 W
РСК	25 W	25 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11765 kWh	15111 kWh

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	47 dB(A)	47 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_s	252 %	197 %
Prated	35.00 kW	35.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 9 of 10

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	6.37	4.99
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	21.20 kW	21.20 kW
COP Tj = -7°C	6.20	4.60
Pdh Tj = +2°C	12.90 kW	12.90 kW
COP Tj = +2°C	6.50	5.30
Pdh Tj = +7°C	8.30 kW	8.30 kW
COP Tj = +7°C	7.50	6.40
Pdh Tj = 12°C	6.90 kW	6.80 kW
COP Tj = 12°C	7.40	6.60
Pdh Tj = Tbiv	35.00 kW	35.00 kW
COP Tj = Tbiv	4.90	3.50
Pdh Tj = TOL	35.00 kW	35.00 kW
COP Tj = TOL	4.90	3.50
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	7 W	7 W
РТО	65 W	45 W
PSB	19 W	19 W
РСК	25 W	25 W

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 10 of 10

	-
I DIG INTORMATION WAS GONGRATED DV THE HUKEVINING	\mathbf{K} database on \mathbf{I} () bec \mathbf{I} () \mathbf{I}
This information was generated by the HP KEYMAR	

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	13541 kWh	17279 kWh

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com