

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	F1x45-12 3x400	Reg. No.	012-043
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	AIT		
Subtype title	F1x45-12 3x400		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	2 kg		

Model: F1145-12 3x400

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.89 kW	10.84 kW
El input	2.70 kW	3.78 kW
COP	4.40	2.91
Indoor water flow rate	2.41 m ³ /h	1.51 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	183 %	141 %
Prated	14.00 kW	14.00 kW
SCOP	4.78	3.73
Tbiv	-5 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	10.80 kW
COP Tj = -7°C	4.70	3.30
Pdh Tj = +2°C	11.60 kW	11.10 kW
COP Tj = +2°C	4.94	3.80
Pdh Tj = +7°C	11.70 kW	11.30 kW
COP Tj = +7°C	5.10	4.10
Pdh Tj = 12°C	11.80 kW	11.50 kW
COP Tj = 12°C	5.14	4.40
Pdh Tj = Tbiv	11.50 kW	10.90 kW
COP Tj = Tbiv	4.75	3.46

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	11.50 kW	10.70 kW
COP Tj = TOL	4.56	3.12
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.50 kW	3.30 kW
Annual energy consumption Qhe	6042 kWh	7785 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	189 %	145 %
Prated	14.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.93	3.83
Tbiv	-15 °C	-14 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.70 kW	11.00 kW
COP Tj = -7°C	4.98	3.70
Pdh Tj = +2°C	11.70 kW	11.20 kW
COP Tj = +2°C	5.12	4.06
Pdh Tj = +7°C	11.80 kW	11.40 kW
COP Tj = +7°C	5.22	4.37
Pdh Tj = 12°C	11.80 kW	11.50 kW
COP Tj = 12°C	4.94	4.50
Pdh Tj = Tbiv	11.60 kW	10.90 kW
COP Tj = Tbiv	4.81	3.49
Pdh Tj = TOL	11.50 kW	10.70 kW
COP Tj = TOL	4.56	3.12
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.50 kW	3.30 kW
Annual energy consumption Q _{he}	6993 kWh	9049 kWh

Model: F1245-12 3x400

General Data

Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.89 kW	10.84 kW
El input	2.70 kW	3.78 kW
COP	4.40	2.91
Indoor water flow rate	2.41 m ³ /h	1.51 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	183 %	141 %
Prated	14.00 kW	14.00 kW
SCOP	4.78	3.73
Tbiv	-5 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	10.80 kW
COP Tj = -7°C	4.70	3.30
Pdh Tj = +2°C	11.60 kW	11.10 kW
COP Tj = +2°C	4.94	3.80
Pdh Tj = +7°C	11.70 kW	11.30 kW
COP Tj = +7°C	5.10	4.10
Pdh Tj = 12°C	11.80 kW	11.50 kW
COP Tj = 12°C	5.14	4.40
Pdh Tj = Tbiv	11.50 kW	10.90 kW
COP Tj = Tbiv	4.75	3.46

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	11.50 kW	10.70 kW
COP Tj = TOL	4.56	3.12
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.50 kW	3.30 kW
Annual energy consumption Qhe	6042 kWh	7785 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	189 %	145 %
Prated	14.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.93	3.83
Tbiv	-15 °C	-14 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.70 kW	11.00 kW
COP Tj = -7°C	4.98	3.70
Pdh Tj = +2°C	11.70 kW	11.20 kW
COP Tj = +2°C	5.12	4.06
Pdh Tj = +7°C	11.80 kW	11.40 kW
COP Tj = +7°C	5.22	4.37
Pdh Tj = 12°C	11.80 kW	11.50 kW
COP Tj = 12°C	4.94	4.50
Pdh Tj = Tbiv	11.60 kW	10.90 kW
COP Tj = Tbiv	4.81	3.49
Pdh Tj = TOL	11.50 kW	10.70 kW
COP Tj = TOL	4.56	3.12
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	2 W	2 W
PTO	30 W	30 W
PSB	7 W	7 W
PCK	30 W	30 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	2.50 kW	3.30 kW
Annual energy consumption Q _{he}	6993 kWh	9049 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	96 %
COP	2.40
Heating up time	00:58 h:min
Standby power input	55.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	230 l

Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	96 %
COP	2.40
Heating up time	00:58 h:min
Standby power input	55.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	230 l