

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	F2120-16	Reg. No.	012-031
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	DTI		
Subtype title	F2120-16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3 kg		
Certification Date	05.05.2020		

## Model: F2120-16

### General Data

Power supply	3x400V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	6.94 kW	7.25 kW
El input	1.43 kW	2.35 kW
COP	4.85	3.08
Indoor water flow rate	1.20 m <sup>3</sup> /h	0.78 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	53 dB(A)	55 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	199 %	153 %
Prated	11.00 kW	12.30 kW
SCOP	5.05	3.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.74 kW	10.91 kW
COP Tj = -7°C	3.41	2.48
Pdh Tj = +2°C	6.47 kW	6.66 kW
COP Tj = +2°C	5.08	3.96
Pdh Tj = +7°C	6.86 kW	5.93 kW
COP Tj = +7°C	5.95	4.69
Pdh Tj = 12°C	6.76 kW	6.49 kW
COP Tj = 12°C	7.36	5.81
Pdh Tj = Tbiv	9.74 kW	10.91 kW
COP Tj = Tbiv	3.41	2.48

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	10.80 kW	11.59 kW
COP Tj = TOL	3.11	2.40
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	12 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.20 kW	0.70 kW
Annual energy consumption Qhe	4508 kWh	6530 kWh

## Colder Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level outdoor	53 dB(A)	53 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	165 %	134 %
Prated	13.00 kW	14.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.19	3.41
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.87 kW	8.47 kW
COP Tj = -7°C	3.50	2.85
Pdh Tj = +2°C	6.20 kW	6.10 kW
COP Tj = +2°C	5.25	4.15
Pdh Tj = +7°C	5.90 kW	6.00 kW
COP Tj = +7°C	5.60	4.80
Pdh Tj = 12°C	6.70 kW	6.40 kW
COP Tj = 12°C	7.00	5.80
Pdh Tj = Tbiv	9.58 kW	10.32 kW
COP Tj = Tbiv	3.15	2.55
Pdh Tj = TOL	8.30 kW	8.69 kW
COP Tj = TOL	2.30	1.94
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	12 W
PSB	25 W	25 W
PCK	37 W	37 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	4.70 kW	5.30 kW
Annual energy consumption Qhe	7639 kWh	10108 kWh