

Page 1 of 6

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	F2120-20	Reg. No.	012-032
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	DTI		
Subtype title	F2120-20		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3 kg		
Certification Date	05.05.2020		



Model: F2120-20

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	6.94 kW	7.25 kW	
El input	1.43 kW	2.35 kW	
СОР	4.85	3.08	
Indoor water flow rate	1.20 m³/h	0.78 m³/h	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 3 of 6 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	55 dB(A)

EN 14825		
	Low temperature	Medium temperature
η _s	199 %	153 %
Prated	11.00 kW	12.30 kW
SCOP	5.05	3.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.74 kW	10.91 kW
COP Tj = -7°C	3.41	2.48
Pdh Tj = +2°C	6.47 kW	6.66 kW
COP Tj = +2°C	5.08	3.96
Pdh Tj = +7°C	6.86 kW	5.93 kW
COP Tj = +7°C	5.95	4.69
Pdh Tj = 12°C	6.76 kW	6.49 kW
COP Tj = 12°C	7.36	5.81
Pdh Tj = Tbiv	9.74 kW	10.91 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 6

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = Tbiv	3.41	2.48
Pdh Tj = TOL	10.80 kW	11.59 kW
COP Tj = TOL	3.11	2.40
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
РТО	7 W	12 W
PSB	25 W	25 W
РСК	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.70 kW
Annual energy consumption Qhe	4508 kWh	6530 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 5 of 6

This information was generated by the HP KEYMARK database on 17 Dec 2020

This information was generated by the HP KETMARK database on 17 Dec 2020				
η _s	165 %	134 %		
Prated	13.00 kW	14.00 kW		
SCOP	4.19	3.41		
Tbiv	-12 °C	-12 °C		
TOL	-22 °C	-22 °C		
Pdh Tj = -7°C	7.87 kW	8.47 kW		
COP Tj = -7°C	3.50	2.85		
Pdh Tj = +2°C	6.20 kW	6.10 kW		
COP Tj = +2°C	5.25	4.15		
Pdh Tj = +7°C	5.90 kW	6.00 kW		
COP Tj = +7°C	5.60	4.80		
Pdh Tj = 12°C	6.70 kW	6.40 kW		
COP Tj = 12°C	7.00	5.80		
Pdh Tj = Tbiv	9.58 kW	10.32 kW		
COP Tj = Tbiv	3.15	2.55		
Pdh Tj = TOL	8.30 kW	8.69 kW		
COP Tj = TOL	2.30	1.94		
Cdh	0.99	0.99		
WTOL	65 °C	65 °C		
Poff	25 W	25 W		
РТО	7 W	12 W		
	1	1		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 6

This information was generated by the HP KEYMARK database on 17 Dec 2020

PSB	25 W	25 W
РСК	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.70 kW	5.30 kW
Annual energy consumption Qhe	7639 kWh	10108 kWh

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com