

 $$\operatorname{\textit{Page}}\ 1$$ of 7 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	S1155-25	Reg. No.	012-C700074	
Certificate Holder				
Name	Nibe AB	Nibe AB		
Address	Box 14	Zip	S-28521	
City	Markaryd	Country	Sweden	
Certification Body	RISE CERT	RISE CERT		
Name of testing laboratory	RISE	RISE		
Subtype title	S1155-25	S1155-25		
Heat Pump Type	Brine/Water and	Brine/Water and Water/Water		
Refrigerant	R410a	R410a		
Mass Of Refrigerant	2.1 kg	2.1 kg		
Certification Date	09.06.2020	09.06.2020		
Testing basis	HP Keymark Scheme Rules rev 7			



Model: S1155-25

General Data	
Power supply	3x400V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4		
Starting and operating test	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	12.68 kW	11.58 kW	
El input	2.71 kW	4.07 kW	
СОР	4.68	2.84	
Indoor water flow rate	2.21 m³/h	1.26 m³/h	

Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	200 %	150 %
Prated	25.00 kW	25.00 kW
SCOP	5.21	3.95
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	22.01 kW	21.71 kW
COP Tj = -7°C	4.24	2.98
Cdh	1.00	1.00
Pdh Tj = +2°C	13.77 kW	13.74 kW
COP Tj = +2°C	5.31	4.00
Cdh	1.00	1.00
Pdh Tj = +7°C	8.88 kW	8.44 kW
COP Tj = +7°C	5.77	4.55
Cdh	1.00	1.00
Pdh Tj = 12°C	7.52 kW	7.42 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textsc{Page}}4 of 7$$ This information was generated by the HP KEYMARK database on 17 Dec 2020

	· · · · · · · · · · · · · · · · · · ·	
COP Tj = 12°C	5.79	4.72
Cdh	1.00	1.00
Pdh Tj = Tbiv	24.19 kW	23.86 kW
COP Tj = Tbiv	4.09	2.76
Pdh Tj = TOL	24.19 kW	23.86 kW
COP Tj = TOL	4.09	2.76
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	o w	0 W
PSB	22 W	22 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	9913 kWh	13063 kWh

Water/Water Heat Pump

Heating



This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	16.94 kW	15.19 kW	
El input	2.67 kW	4.12 kW	
СОР	6.34	3.69	
Indoor water flow rate	2.95 m³/h	1.66 m³/h	

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

	Low temperature	Medium temperature
η_{S}	285 %	197 %
Prated	34.00 kW	31.00 kW
SCOP	7.32	5.14
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	30.08 kW	27.60 kW
COP Tj = -7°C	5.40	3.60

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 17 Dec 2020

		1 00
Cdh	1.00	1.00
Pdh Tj = +2°C	18.30 kW	16.90 kW
$COP Tj = +2^{\circ}C$	7.50	5.10
Cdh	0.99	0.99
Pdh Tj = $+7^{\circ}$ C	11.80 kW	10.90 kW
$COP Tj = +7^{\circ}C$	8.50	6.36
Cdh	0.98	0.99
Pdh Tj = 12°C	8.60 kW	8.30 kW
COP Tj = 12°C	8.70	6.60
Cdh	0.97	0.98
Pdh Tj = Tbiv	34.00 kW	31.00 kW
COP Tj = Tbiv	5.10	3.42
Pdh Tj = TOL	34.00 kW	31.00 kW
COP Tj = TOL	5.10	3.42
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	30 W	20 W
PSB	22 W	22 W
РСК	8 W	8 W
Supplementary Heater: Type of energy input	electric	electric
Supplementary Heater: PSUP	0.00 kW	0.00 kW



Page 7 of 7
This information was generated by the HP KEYMARK database on 17 Dec 2020

annual energy consumption Qhe	9598 kWh	12469 kWh
-------------------------------	----------	-----------